

K. Dis /C4/1994/2023



Taluk Office
Vellore
Dated : 14.06.2023

FORM - D

Form of licence under sub section (1) of Section 6 of the Tamil Nadu Public Building (Licencing) Act 1965 (Tamil Nadu Act 13 of 1965) referred to in rule 6 of the Tamil Nadu Public Building (Licencing Rules 1966)

Licence No. : 55/2023

Fees : Rs. 1050/- Remitted in
E-Challan No.05920
Dt : 14.06.2023


Licence is hereby granted to **VELAMMAL BODHI CAMPUS**, Ezhil Nagar Main Road, Allapuram, Vellore Taluk and District for the purpose and in respect of the Building specified in the statement below and subject to the conditions for the period mentioned here under.

1. The period of validity of the Licence is from **01.06.2023 to 31.05.2026**.
2. This issued for the Building located at Ezhil nagar Main Road, Allapuram, Vellore Taluk and District.
3. The Building should be used for Educational purpose only and not for other purpose.
4. No additions or alterations should be made before the expiry of the period of the Licence.
5. If any repairs are to be carried out, care should be taken that repairs do not affect the dimension of the Building.
6. The Fire extinguishers should be refilled before the date of expiry.
7. The Licensee is advised to obtain necessary Fire certificate and Sanitary certificate from the authorities concerned.


TAHSILDAR
VELLORE
VELLORE

STATEMENT TO ACCOMPANY THE LICENCE

Location of the Building Door No, Street and Name of the place.	Purpose for which the building is licenced and to be used as a public building	Number of persons to be accommodated
Velammal Bodhi Campus Ezhil Nagar Main Road, Allapuram Vellore Taluk and District Survey No. 43/28	Educational purpose	3000 (Three Thousand Only)




TAHSILDAR
VELLORE
VELLORE

14/06/23

Er. D.NATARAJAN, B.E.(CIVIL),M.I.E.,
STRUCTURAL ENGINEER, CHARTERED ENGINEER
REGISTERED&APPROVED ENGINEER
BY THE BOARD OF ENGINEERS, TAMIL NADU.
PANEL ENGINEER CLASS IA, VELLORE DISTRICT

Res: 50-A,3rd Street, S.S.Nagar,
Palanipet, Arakkonam - 631002
Off: 400, Nethaji Bose 4th Street,
Phase III, TNHB, Sathuvachari,
Vellore - 632 009
Cell: 9443106470, 8056631312
Email : dnatarajan8@gmail.com

Ref: Collector, VLR Lr. No. டி.க.அ.6/31531/2013 Dated : 23.09.2015

STRUCTURAL SOUNDNESS CERTIFICATE RELATING TO SCHOOL
STATEMENT ACCOMPANYING FORM - A

1. Name of the School and Door no of the Building : **VELAMMAL BODHI CAMPUS**
Ezhil Nagar Main Road, Allapuram, Vellore Corporation,
Vellore Taluk, Vellore District - 632 002.
2. Location (street No. Ward No. Name of place, ie., Corporation, Municipality/ Panchayat Union/ Panchayat/Township/Cantonment) : S.F. No. 43/28
Ezhil Nagar Main Road, Allapuram,
Vellore Corporation, Vellore Taluk,
Vellore District - 632 002.
3. Year of construction : **BLOCK A** : Ground Floor : RCC : 2016
First & Second Floor : RCC : 2017
BLOCK B : Ground, First & Second Floor : RCC : 2018
4. Approximates cost of construction as per current rate : Rs. 580.00 Lakhs
5. Purpose for which the building is being used or proposed to be used : Educational Purpose
6. Purpose for which the building has hitherto been used : Educational Purpose
7. Details of construction of the building (particulars of the foundation, soil, Specification of various parts under
(i) Foundation : RCC Column & Isolated Footing
(ii) Basement : RCC Column, Plinth Beam & Brick in CM
(iii) Superstructure : RCC Column & Brick in CM
(iv) Floor & Roof are to be given : Flooring: Ceramic Tiles
Roof: RCC Slab
8. Period for which the license is require : May be issued FROM **01.06.2023 to 31.05.2026**
(For Three years only)
9. Number of persons to be accommodated : **Three Thousand (3000) Pupils only**
Refer "ANNEXURE" to this
Place : Vellore
Date : 27-04-2023

Signature of the Correspondent

CORRESPONDENT
VELAMMAL BODHI CAMPUS
EZHIL NAGAR, PERIYA ALLAPURAM,
TAMIL NADU (P.O.), VELLORE-632001.

Signature of the Engineer

Er. D. NATARAJAN, B.E.,(CIVIL) MIE
Chartered Engineer
Panel Engineer Class 1A
Vellore District
400, Nethaji Bose 4th Street,
Phase III, TNHB, Sathuvachary
Vellore-632 009
Cell: 94431 06470, 8056631312

மரம் வளர்ப்போம்.



மழை பெறுவோம்

ANNEXURE TO "STATEMENT ACCOMPANYING FORM – A"

Certified that no addition or alteration has been made to the existing building or portion of a building for which this application has been made. I undertake to obtain a fresh license in case any addition or alteration is made to the existing building or portion of the building. I also undertake to obtain a fresh license if the purpose for which the license was granted for the use of the building or portion of the building originally is change or altered subsequently.

This is further to certify that no thatched buildings are used for conducting any classes within the School premises. Any thatched building constructed/used after issue of this certificate, I would be held responsible for fire accident/mishap that may occur later and that I am aware that it is a punishable crime.


Signature of the Correspondent

CORRESPONDENT
VELAMMAL BODHI CAMPUS
EZHIL NAGAR, PERIYA ALLAPURAM,
THORAPADI (P.O.), VELLORE-632001.

Er. D. NATARAJAN, B.E.(CIVIL),M.I.E.,
STRUCTURAL ENGINEER, CHARTERED ENGINEER
REGISTERED & APPROVED ENGINEER
BY THE BOARD OF ENGINEERS, TAMIL NADU,
PANEL ENGINEER CLASS IA, VELLORE DISTRICT

Res: 50-A, 3rd Street, S.S.Nagar.
Palanipet, Arakkonam - 631002
Off: 400, Nethaji Bose 4th Street,
Phase III, TNHB, Sathuvachari,
Vellore - 632 009
Cell: 9443106470, 8056631312
Email : dnatarajan8@gmail.com

FORM - B

STATEMENT ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

VELAMMAL BODHI CAMPUS, ALLAPURAM, VELLORE CORPORATION

FORM OF CERTIFICATE OF STRUCTURAL SOUNDNESS UNDER SUB SECTION (B) OF SECTION OF (4) OF SECTION 4 OF THE TAMIL NADU PUBLIC BUILDING (LICENSING ACT 1965 TAMIL NADU ACT 1 OF 1965) REFERRED TO IN RULE OF THE TAMIL NADU PUBLIC (LICENSING) RULES 1966.

I Certify, that I have inspected the building mentioned in the statement and furnished below its salient technical features.

1. **Foundation:**
 - i. **Depth below ground level** : 07 ft below G.L
 - ii. **Nature of soil met out in the foundation** : Sandy Loam
 - iii. **Pressure at foundation** : 09 tones / Sq.m
 - iv. **Probable safe bearing capacity of the foundation** : 17 tones / Sq.m
2. **Superstructure:**
 - i. **Maximum stress in most critical Sections of masonry and concrete**
 - a) R.C.C Concrete : 35 Kg / Sq.cm
 - b) Masonry : 08 tones / Sq.m.
 - ii. **Nature of masonry and concrete And its safe permissible stress**
 - : Brick masonry in cm: 30 tones / Sq.m.
 - R.C.C : 40 Kg / Sq.cm.

The Structural of the building has been verified by me with reference to ISIS loading standards 875 (Latest version) and other relevant Indian Standard code of practices I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. This Certificate does not include any Thatched sheds and also any flammable building material utility. Proper toilet facilities to be provided as per norms. If any thatched sheds are found at a later period after issue of this certificate / License this certificate gets invalid. A license may be granted for the period from 01.06.2023 to 31.05.2026.


Signature of the Correspondent

CORRESPONDENT
VELAMMAL BODHI CAMPUS
EZHIL NAGAR, PERIYA ALLAPURAM,
THORAPADI (P.O.), VELLORE-632001.


Signature of the Engineer

Er. D. NATARAJAN, B.E.,(CIVIL) MIE
Chartered Engineer
Panel Engineer Class 1A
Vellore District

400, Nethaji Bose 4th Street,
Phase III, TNHB, Sathuvachary
Vellore-632 009
Cell: 94431 06470, 8056631312

மரம் வளர்ப்போம்.

மழை பெறுவோம்

Er. D.NATARAJAN, B.E.(CIVIL),M.I.E.,
STRUCTURAL ENGINEER, CHARTERED ENGINEER
REGISTERED&APPROVED ENGINEER
BY THE BOARD OF ENGINEERS, TAMIL NADU.
PANEL ENGINEER CLASS IA, VELLORE DISTRICT

Res: 50-A,3rd Street, S.S.Nagar.
Palanipet, Arakkonam – 631002
Off: 400, Nethaji Bose 4th Street,
Phase III, TNHB, Sathuvachari,
Vellore – 632 009
Cell: 9443106470, 8056631312
Email : dnatarajan8@gmail.com

FORM – C

STATEMENT ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

VELAMMAL BODHI CAMPUS, ALLAPURAM, VELLORE CORPORATION

Form of certificate of structural soundness under sub section (b) of section of 4 of the madras Public Buildings (Licensing Act 1963 Madras Act 13 of 1965 referred to in rule 4 of the Madras Public building (Licensing) rules 1977.

Certify that have inspected the building mentioned in the statement below and I have satisfied myself the building is structural sound to be used as a public building for the purpose note in the statement. The structural soundness of the building has been verified taking into account the loading as per latest Indian standard 875.

Location of the building door No. street name and name of the place	Age of the building	Value of the Building	No. of Storeys	Short Description of structure steel RCC framed or load bearing masonry
1.	2.	3.	4.	5.
VELAMMAL BODHI CAMPUS Ezhil Nagar Main Road, Allapuram, Vellore Corporation, Vellore Taluk, Vellore District – 632 002.	BLOCK A : Ground Floor : RCC : 07 Years First & Second Floors : RCC : 06 Years BLOCK B : GF, FF & SF RCC : 05 Years	Rs. 580.00 Lakhs	Ground Floor + 2	RCC Framed Structure

Purpose for which the building is certified for use	The Period for which the building will be structurally sound	No of the persons to be accommodated	Remarks
6.	7.	8.	9.
Educational Purpose	License may be issued for the period of Three Years from 01.06.2023 to 31.05.2026	3000 Pupils only	Building is structurally sound

Signature of the Correspondent

CORRESPONDENT
VELAMMAL BODHI CAMPUS
EZHIL NAGAR, PERIYA ALLAPURAM,
THORAPADI (P.O.), VELLORE-632001.

Signature of the Engineer

Er. D. NATARAJAN, B.E.,(CIVIL) MIE
Chartered Engineer
Panel Engineer Class 1A
Vellore District
400, Nethaji Bose 4th Street,
Phase III, TNHB, Sathuvachary
Vellore-632 009
Cell: 94431 06470, 8056631312

மரம் வளர்ப்போம்.

மழை பெறுவோம்

Er. D. NATARAJAN, B.E.(CIVIL), M.I.E.,
STRUCTURAL ENGINEER, CHARTERED ENGINEER
REGISTERED & APPROVED ENGINEER
BY THE BOARD OF ENGINEERS, TAMIL NADU,
PANEL ENGINEER CLASS IA, VELLORE DISTRICT

Res: 50-A, 3rd Street, S.S. Nagar,
Palanipet, Arakkonam - 631002
Off: 400, Nethaji Bose 4th Street,
Phase III, TNHB, Sathuvachari,
Vellore - 632 009
Cell: 9443106470, 8056631312
Email : dnatarajan8@gmail.com

FORM - E

STATEMENT ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS
VELAMMAL BODHI CAMPUS, ALLAPURAM, VELLORE CORPORATION

Form of report to be made to the competent authority by inspecting authorities or officers appointed under other acts under section 28 of the Tamil Nadu Public Buildings (Licensing) Act, 1965 (Tamil Nadu Act XIII of 1965) referred to in rule 7 of the Tamil Nadu Public Buildings (Licensing) Rules, 1966.

1. Name and Designation of inspecting authority or officer appointed or having jurisdiction under any other Act or law. : Er. D. NATARAJAN, B.E. (CIVIL), M.I.E. STRUCTURAL ENGINEER, CHARTERED ENGINEER REGISTERED & APPROVED ENGINEER BY THE BOARD OF ENGINEERS, TAMILNADU. PANEL ENGINEER CLASS IA, VELLORE DISTRICT
2. Location of the building inspected (Door Number, Street Number, Name of place, i.e. Municipal Corporation / Municipality / Panchayat or Panchayat Union/Township/Cantonment.) : S.F. No. 43/28 Ezhil Nagar, Main Road, Allapuram. Vellore Corporation, Vellore Taluk, Vellore District - 632 002
3. Date of Inspection : 12-04-2023
4. Purpose for which the building is used : Educational Purpose
5. Nature of defects noticed : No defects found
6. Suggestions for rectifying defects : Nil
7. If in a dangerous condition, immediate Steps recommended to be taken : Nil


Signature of the Engineer
Er. D. NATARAJAN, B.E., (CIVIL) MIE
Chartered Engineer
Panel Engineer Class 1A
Vellore District
400, Nethaji Bose 4th Street,
Phase III, TNHB, Sathuvachary
Vellore-632 009
Cell: 94431 06470, 8056631312

மரம் வளர்ப்போம்.

மழை பெறுவோம்